



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM # 4

11/16/2021

Solicitation #7658826

Title: Bathroom Renovations CCRI Knight Campus

Submission Deadline: November 23, 2021 @ 11:00 AM

Per the issuance of ADDENDUM #4 the following are noted:

CLARIFICATION:

Please find Addendum #4 prepared by Aharonian & Associates Architects Inc.
(see attached)

No further questions will be entertained.

Interested Parties should monitor this website on a regular basis, for any additional information that may be posted.

Gary P. Mosca
Chief Buyer



AHARONIAN
& ASSOCIATES, INC.
Architects

November 16, 2021

TO: All Bidders

RE: CCRI Knight Campus: Bathroom Renovations
400 East Ave
Warwick, RI 02886

ADDENDUM #04

The Contract Documents for the above referenced Project are hereby modified per the following. All other Drawing items not addressed herein shall remain in full effect. The Bidder shall acknowledge the receipt of this Addendum on the Bid Form.

CLARIFICATION

1. **Project Manual Section 01 10 00 Summary of Work - Exhibit C Supplemental Scope Notes and Design Intent:**

Replace Note #7 in its entirety with the following text. "The construction documents provide diagrammatic routes intended for a complete sanitary waste drainage system & upgrades to the hot water recirculation system. Means and Methods for completing the replacement of the plumbing pipes is up to the vendor and shall be coordinated with the Architect during the submittal process. The vendor is required to include in their bid proposal a complete replacement of the plumbing lines from the roof line down to the basement as dictated by the project scope of work."

2. **The Contract Documents indicate that there are no Bathrooms on the 5th Floor of the Building. The only possibility for work on this floor is sanitary pipes running down from the 6th Floor Bathrooms to the 4th Floor. For all purposes there is no 5th Floor, which is a mechanical space in the mega structure. In the Round Building there are no bathrooms on the 5th Floor mezzanine, so that area would not apply.**

ATTACHMENTS

None