

Project Leaders A Division of Colliers Engineering & Design

March 26, 2025

Pawtucket School District 286 Main St Pawtucket, RI 02860

Subject: Charles E. Shea High School

C2024-008 Shea HS Fire Code Upgrades RFP Addendum #2

• **General Comment #1:** In any spaces where new sprinkler lines are to be installed any devices that are made unnecessary due to the new sprinkler coverage are to be removed. Please carry a \$25,000 allowance to account for this scope of work.

Sincerely,

atrioh H. Damour

Patrick Damour Project Manager, Project Management Services